

Emission Test Certificate

Thursday March 22nd, 2007

Supplier: Verosol Australia Pty Ltd

2 Garema Circuit

Kingsgrove New South Wales 2208

Sample Description: Verosol SilverScreen fabric for Roller Blinds (PVC Blind).

Date Tested: March 2007

Test Method: ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Green Building Council of Australia Green Star Office Interior Specification	Total Volatile Organic Compound Specific Area Emission Rate
< 0.5 mg/m ² /hr (7 days)	0.05 mg/m ² /hr



Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant